

**Product: Residential K-Base**

**Subject: 2K Test Adapter Advisory**

**Date: 1/7/2005**

#### **Description:**


A new-design baseplate will soon be introduced on FOCUS® form 2K meters. This design utilizes two encased transformers in the meter baseplate opposed to the old design that used one large transformer. The old design was used on MS-2K and Altimus 2K meters.

This new design results in a need to modify existing 2K test adapters in order to work with the FOCUS 2K meter. Attached are photos comparing the old-style and new-style adapters and 2K baseplates.



New Adapter

Old Adapter



New K-Base

Old K-Base

All 2K Test Adapters, part no. 9707-8009, purchased from this date forward will be of the new design. **The new adapter design adapts to ALL 2K meters including MS, Altimus and FOCUS.**

Please contact Landis+Gyr Inc. for information regarding modification of existing old-style adapters in your possession.

**If you have additional questions or comments about this notice, please contact Landis+Gyr's technical support center at 800-777-2774 or at [technicalsupport@us.landisgyr.com](mailto:technicalsupport@us.landisgyr.com)**

#### **CONFIDENTIAL INFORMATION:**

**This document, and any information contained herein is confidential. It shall not be loaned, copied, disclosed, or used for manufacturing, or other purposes whatsoever without prior written consent of Landis+Gyr Inc .**